



FORM B 13.3

FIRE SAFETY CERTIFICATE RENEWAL (FSCR)

(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/RFOGDN/2021/00008565

Date: 30/12/2023

FSC Safety Certificate Renewal (FSCR) No. FSCA/O/RFOGDN/2021/00008565/R1

Building Occupancy/Category: Educational (non-residential)

To,

patel vishal

WARD NO 7-A WARD NO-7A GANDHIDHAM GANDHIDHAM Kachchh 370240

Fire Region: Rajkot RFO

Mobile No: 9558541439 Email ID: vishalgorasiya1997@gmail.com

This has reference to your Application No. 2023/00043117 dated 26/12/2023 for Fire Safety Certificate Renewal (FSCR) for the building/premise SHRI AMARCHAND SINGHVI INTERNATIONAL SCHOOL (name of the Building/ Project), as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number:
4. Village Name: GANDHIDHAM
5. Name of Block(s): SHRI AMARCHAND SINGHVI INTERNATIONAL SCHOOL

The building/premise was inspected on 30/12/2023 and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on 30/12/2023
2. Six monthly inspection was done on 30/12/2023

The Fire Safety Certificate is renewed for a period of **two (2)** years upto 30/12/2025 in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.



Digitally Verified

Digitally verified by: Dipen Rajendrabhai Hansora
Fire Safety Officer - General (FSO-G)
2021/001355

Date: 30/12/2023
Time: 02:18 PM



FSCA/O/RFOGDN/2021/00008565/R1

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at www.gujfiresafetycop.in.

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.